

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 194

Dated: 27/06/23

It is certified that an inspection team headed by Shri Rajesh Ratnakar Sub Engineer

(Name of Officers with designation) from PHE Maintt Sub Division

Lashkar East Gwalior

(Name of Department/ Office) inspected the Saraswati Shiksha Mandir

Redarpur Gwalior

(Name & Address of the school) on 27/06/2023 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year

Signature with Seal: [Signature]

Name : Mahendra Prasad

Designation : Assistant Engineer

सहायक यंत्री

Assistant Engineer उत्तर प्रदेश संघारण उपखण्ड लखनऊ पूर्व

the Govt. Public Health Department (संविधान)

Authorised officer of the Local Body

Name & Address of the Office / Department :

To The Principal
Saraswati Shiksha Mandir
CBSE
Redarpur Gwalior (M.P.)

(Name & Address of the Institution)


* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


**Public Health Engineering Department District Water-
Testing Laboratory Gwalior**
Test Report

Type of sample: Water Sample		Particular of sample : collected / not collected by PHED	
Particular of sender:- Saraswati Shishu Mandir Kedarpur Gwalior (M P)			
Sample No.	Place of Collection and Details of Sample	Date of collection	
1	School Bore Well	12-05-2023	
2	-	-	
3	-	-	
4	-	-	
Particular of Sample :		Time of Receipt: 01:45 PM	
Date of Receipt: 12-05-2023		Date of Analysis: 15-05-2023	
Lab Reference No:			
Nature of Study – Chemical and Bacteriological Analysis			

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit In the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
PHYSICAL TESTE								
1	Turbidity	NTU	1.0	5.0	2.7	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionabl	-	-	-
4	Temperature	C°	-	-	-	-	-	-
CHEMICAL TESTE								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.1	-	-	-
6	Alkalinity	Mg/L	200	600	362	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	112	-	-	-
8	Nitrate as No3	Mg/L	45	45	-	-	-	-
9	Total hardness	Mg/L	200	600	362	-	-	-
10	Calcium as Ca	Mg/L	75	200	85	-	-	-
11	Magnesium as mg	Mg/L	30	100	36.4	-	-	-
12	Iron	Mg/L	0.3	1.0	0.2	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	-	-	-	-
14	T.D.S.	Mg/L	500	2000	598	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.33	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	-	-	-	-
BECT. FEACAL TESTE								
17	MPN of coliform	per 100 ml	Nil		-	-	-	-
18	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-

- 6- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- 7- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" under the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- 8- The results refer only to tested samples and parameters tested
- 9- samples will be stored for a period of 10 days from the date of issue of report.
- 10- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.


Signature of Analyst
District Lab Gwalior
PHE Division Gwalior


Lab in charge
P.H.E.D. Division Gwalior (M.P.)
District Water Testing Laboratory
P.H.E Division, Gwalior (M.P)

No. 157 /PHED/ Date :- 17/05/2023

कार्यालय आयुक्त, नगर पालिक निगम, ग्वालियर

(स्वास्थ्य विभाग, फूलबाग मैदान परिसर के पास, गोपाल मंदिर के पीछे)

क्रमांक 2526 / 06 / 21 / 2 / 10 / स्वा.वि. / 23


ग्वालियर दिनांक 1/6/2023



स्वच्छता प्रमाण - पत्र

प्रमाणित किया जाता है कि संस्थान-प्राचार्य, सरस्वती शिशु मंदिर केदारपुर ग्वालियर, शिवपुरी लिंक रोड - ग्वालियर का नगर पालिक निगम अधिनियम के प्रावधानान्तर्गत निरीक्षण किया। संस्थान में समुचित स्वच्छता पाई गई, जिसके फलस्वरूप यह स्वच्छता प्रमाण पत्र इस शर्त के साथ जारी किया जाता है कि सोलिड वेस्ट का निष्पादन सदैव नियमानुसार कराना होगा एवं भविष्य में निरीक्षण के दौरान स्वच्छता एवं सुरक्षा में किसी भी प्रकार की कमी पाई गई तो यह प्रमाण -पत्र स्वतः निरस्त मान्य किया जावेगा। यह स्वच्छता प्रमाण पत्र वर्तमान वित्तीय वर्ष (31 मार्च 2024) के लिए ही मान्य होगा।

श्री. क. र. -
01/06/2023


उपायुक्त (स्वा.)
नगर निगम, ग्वालियर